



ICP: Results of Lead in Drinking Water

Client	<u>Lead Testing Services</u>	Site Address	<u>1231 N Broad St, Philadelphia, PA</u>	Sample Date	<u>7/23/2022</u>
Project #	<u>221899</u>			Sample Received Date	<u>7/25/2022</u>
Collected By	<u>Lead Testing Services</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>7/27/2022</u>

Sample Number	Collected	Location / Description	Lead (ppb)
221899-07-023-01-01	7/23/2022 08:00	5th Floor - Staff Bathroom - Sink Flow	< RL
221899-07-023-01-02	7/24/2022 08:02	5th Floor - Staff Bathroom - Sink Standing	< RL
221899-07-023-01-03	7/24/2022 08:03	5th Floor - Men's #1 - Standing	< RL
221899-07-023-01-04	7/23/2022 08:03	5th Floor - Men's #1 - Flushing	< RL
221899-07-023-01-05	7/24/2022 08:04	5th Floor - Men's #2 - Standing	< RL
221899-07-023-01-06	7/23/2022 08:04	5th Floor - Men's #2 - Flushing	< RL
221899-07-023-01-07	7/23/2022 08:05	5th Floor - Women's #1 - Standing	6.357
221899-07-023-01-08	7/23/2022 08:05	5th Floor - Women's #1 - Flushing	< RL
221899-07-023-01-09	7/23/2022 08:06	5th Floor - Women's #2 - Standard	1.7615
221899-07-023-01-10	7/23/2022 08:06	5th Floor - Women's #2 - Flushing	< RL
221899-07-023-01-11	7/23/2022 08:07	Starbucks Sink #1 - Standing	2.843
221899-07-023-01-12	7/23/2022 08:07	Starbucks Sink #2 - Flushing	< RL
221899-07-023-01-13	7/23/2022 08:08	Starbucks Sink #1 - Flushing	< RL
221899-07-023-01-14	7/23/2022 08:08	Starbucks Sink #2 - Standing	6.539
221899-07-023-01-15	7/23/2022 08:09	Student Bath Sink #1 - Standing	1.521
221899-07-023-01-16	7/23/2022 08:09	Student Bath Sink #1 - Flushing	< RL
221899-07-023-01-17	7/23/2022 08:09	Student Sink #2 - Standing	< RL
221899-07-023-01-18	7/23/2022 08:09	Student Sink #2 - Flushing	< RL
221899-07-023-01-19	7/23/2022 08:10	5th Floor Water Fountain - Standing	< RL
221899-07-023-01-20	7/23/2022 08:10	5th Floor Water Fountain - Flushing	< RL
221899-07-023-01-21	7/23/2022 08:20	4th Floor - Kitchen Sink #1 - Standing	< RL
221899-07-023-01-22	7/23/2022 08:20	4th Floor - Kitchen Sink #1 - Flushing	3.105
221899-07-023-01-23	7/23/2022 09:21	4th Floor - Kitchen Sink #2 - Standing	< RL
221899-07-023-01-24	7/23/2022 08:22	4th Floor - Kitchen Sink #2 - Flushing	< RL
221899-07-023-01-25	7/23/2022 08:22	4th Floor - Kitchen Sink #3 - Standing	< RL
221899-07-023-01-26	7/23/2022 08:22	4th Floor - Kitchen Sink #3 - Flushing	< RL
221899-07-023-01-27	7/23/2022 08:22	4th Floor - Kitchen Sink #4 - Standing	< RL
221899-07-023-01-28	7/23/2022 08:22	4th Floor - Kitchen Sink #4 - Flushing	< RL
221899-07-023-01-29	7/23/2022 08:22	4th Floor - Kitchen Sink #5 - Standing	< RL
221899-07-023-01-30	7/23/2022 08:22	4th Floor - Kitchen Sink #5 - Standing Sink	< RL
221899-07-023-01-31	7/23/2022 08:22	4th Floor - Men's Sink #1 - Standing	1.992
221899-07-023-01-32	7/23/2022 08:24	4th Floor - Men's Sink #1 - Flushing	< RL
221899-07-023-01-33	7/23/2022 08:40	4th Floor - Men's Sink #2 - Standing	< RL



ICP: Results of Lead in Drinking Water

Client	<u>Lead Testing Services</u>	Site Address	<u>1231 N Broad St, Philadelphia, PA</u>	Sample Date	<u>7/23/2022</u>
Project #	<u>221899</u>			Sample Received Date	<u>7/25/2022</u>
Collected By	<u>Lead Testing Services</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>7/27/2022</u>

Sample Number	Collected	Location / Description	Lead (ppb)
221899-07-023-01-34	7/23/2022 08:40	4th Floor - Men's Sink #2 - Flushing	< RL
221899-07-023-01-35	7/23/2022 08:40	4th Floor - Women's #1 - Standing	< RL
221899-07-023-01-36	7/23/2022 08:41	4th Floor - Women's #1 - Flushing	< RL
221899-07-023-01-37	7/23/2022 08:42	4th Floor - Women's #2 - Standing	< RL
221899-07-023-01-38	7/23/2022 08:42	4th Floor - Women's #2 - Flushing	2.285
221899-07-023-01-39	7/23/2022 08:42	4th Floor - Women's #3 - Standing	10.2115
221899-07-023-01-40	7/23/2022 08:42	4th Floor - Women's #3 - Flushing	< RL
221899-07-023-01-41	7/23/2022 08:42	4th Floor - Fountain - Standing	< RL
221899-07-023-01-42	7/23/2022 08:42	4th Floor - Fountain - Flushing	< RL
221899-07-023-01-43	7/23/2022 08:45	4th Floor - Women's #1 - Standing Ex	< RL
221899-07-023-01-44	7/23/2022 08:45	4th Floor - Women's #1 - Flushing Ex	< RL
221899-07-023-01-45	7/23/2022 08:46	4th Floor - Women's #2 - Standing Ex	< RL
221899-07-023-01-46	7/23/2022 08:46	4th Floor - Women's #2 - Flushing Ex	4.583
221899-07-023-01-47	7/23/2022 08:47	4th Floor - Women's #3 - Standing Ex	< RL
221899-07-023-01-48	7/23/2022 08:47	4th Floor - Women's #3 - Flushing Ex	2.067
221899-07-023-01-49	7/23/2022 08:50	4th Floor - Men's #1 - Standing	< RL
221899-07-023-01-50	7/23/2022 08:51	4th Floor - Men's #1 - Flushing	< RL
221899-07-023-01-51	7/23/2022 08:51	4th Floor - Men's #2 - Standing	< RL
221899-07-023-01-52	7/23/2022 08:51	4th Floor - Men's #2 - Flushing	3.099
221899-07-023-01-53	7/23/2022 08:52	4th Floor - Men's #3 - Standing	4.117
221899-07-023-01-54	7/23/2022 08:52	4th Floor - Men's #3 - Flushing	1.8605
221899-07-023-01-55	7/23/2022 08:54	4th Floor - Fountain - Standing	< RL
221899-07-023-01-56	7/23/2022 08:54	4th Floor - Fountain - Flushing	< RL
221899-07-023-01-57	7/23/2022 08:50	4th Floor - Kitchen - Standing Ex	< RL
221899-07-023-01-58	7/23/2022 08:50	4th Floor - Kitchen - Flushing Ex	< RL
221899-07-023-01-59	7/23/2022 08:52	3rd Floor - Men's #1 - Standing	< RL
221899-07-023-01-60	7/23/2022 08:52	3rd Floor - Men's #1 - Flushing	< RL
221899-07-023-01-61	7/23/2022 08:52	3rd Floor - Men's #2 - Standing	< RL
221899-07-023-01-62	7/23/2022 08:53	3rd Floor - Men's #2 - Flushing	< RL
221899-07-023-01-63	7/23/2022 08:53	3rd Floor - Men's #3 - Standing	< RL
221899-07-023-01-64	7/23/2022 08:53	3rd Floor - Men's #3 - Flushing	< RL
221899-07-023-01-65	7/23/2022 08:50	3rd Floor - Kitchen #1 - Standing	< RL
221899-07-023-01-66	7/23/2022 08:50	3rd Floor - Kitchen #1 - Flushing	< RL



ICP: Results of Lead in Drinking Water

Client	<u>Lead Testing Services</u>	Site Address	<u>1231 N Broad St, Philadelphia, PA</u>	Sample Date	<u>7/23/2022</u>
Project #	<u>221899</u>			Sample Received Date	<u>7/25/2022</u>
Collected By	<u>Lead Testing Services</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>7/27/2022</u>

Sample Number	Collected	Location / Description	Lead (ppb)
221899-07-023-01-67	7/23/2022 09:05	3rd Floor - Women's #1 - Standing	< RL
221899-07-023-01-68	7/23/2022 09:05	3rd Floor - Women's #1 - Flushing	< RL
221899-07-023-01-69	7/23/2022 09:05	3rd Floor - Women's #2 - Standing	1.723
221899-07-023-01-70	7/23/2022 09:05	3rd Floor - Women's #2 - Flushing	< RL
221899-07-023-01-71	7/23/2022 09:10	3rd Floor - Fountain - Standing	< RL
221899-07-023-01-72	7/23/2022 09:10	3rd Floor - Fountain - Flushing	< RL
221899-07-023-01-73	7/23/2022 09:20	2nd Floor - Fountain - Standing	< RL
221899-07-023-01-74	7/23/2022 09:21	2nd Floor - Fountain - Flushing	< RL
221899-07-023-01-75	7/23/2022 09:25	2nd Floor - Women's #1 - Standing	< RL
221899-07-023-01-76	7/23/2022 09:26	2nd Floor - Women's #1 - Flushing	< RL
221899-07-023-01-77	7/23/2022 09:30	2nd Floor - Women's #2 - Standing	< RL
221899-07-023-01-78	7/23/2022 09:30	2nd Floor - Women's #2 - Flushing	< RL
221899-07-023-01-79	7/23/2022 09:46	2nd Floor - Women's Staff #1 - Standing	< RL
221899-07-023-01-80	7/23/2022 09:46	2ndFloor - Women's Staff - Flushing	< RL
221899-07-023-01-81	7/23/2022 09:46	2nd Floor - Men's #1 - Standing	< RL
221899-07-023-01-82	7/23/2022 09:45	2nd Floor - Men's #1 - Flushing	< RL
221899-07-023-01-83	7/23/2022 09:45	2nd Floor - Men's #2 - Standing	< RL
221899-07-023-01-84	7/23/2022 09:45	2nd Floor - Men's #2 - Flushing	< RL
221899-07-023-01-85	7/23/2022 09:45	1st Floor #1 - Standing	< RL
221899-07-023-01-86	7/23/2022 09:45	1st Floor #1 - Flushing	4.57

Sample Count 86

James A. Weltz, CIH, Technical Director

Reporting limit is 1.39 ppb. Criterion Laboratories, Inc. bears no responsibility for sample collection activities of non-Criterion personnel. This report relates only to the samples reported above, and when reproduced, must be in its entirety. Estimated accuracy, precision and uncertainty data available on request. QC data associated with this sample set is within acceptable limits. Samples were received in good condition, unless otherwise noted.

Note: If your project number ends with an "R", it is a revised report and replaces the original document in full. Samples are analyzed by Criterion Laboratories, Inc. using EPA Method 200.5: Determination of Trace Elements in Drinking Water by Axially Viewed Inductively Coupled Plasma - Atomic Emission Spectrometry and CLI Method 446



ICP: Results of Lead in Drinking Water

Client	<u>Lead Testing Services</u>	Site Address	<u>1231 N Broad St, Philadelphia, PA</u>	Sample Date	<u>7/23/2022</u>
Project #	<u>221899</u>			Sample Received Date	<u>7/25/2022</u>
Collected By	<u>Lead Testing Services</u>	Analyzed By	<u>Schwab, Andrew</u>	Sample Analysis Date(s)	<u>7/27/2022</u>

Criterion Laboratories, Inc. (ID 100424) is accredited by the AIHA Laboratory Accreditation Programs (AIHA-LAP), LLC in the IHLAP; EMLAP and ELLAP accreditation programs for Polarized Light Microscopy (PLM), Phase Contrast Microscopy (PCM); Air-Direct Examination; and Airborne Dust, Paint, Settled Dust by Wipe and Soil for Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. Additionally, Criterion Laboratories, Inc. is certified by the Center for Disease Control (CDC) Environmental Legionella Isolation Techniques Evaluation (ELITE) Program for the determination of Legionella in water by culture and holds accreditation from the National Voluntary Laboratory Accreditation Program (NVLAP ID 102046-0) for the determination of asbestos in bulk samples by Polarized Light Microscopy (PLM). This test report must not be used to claim product endorsement by NVLAP, NIST, AIHA or any agency of the US Government. Unless specifically listed as above, these test results are not covered under AIHA-LAP, LLC, 100424 accreditation.

THIS IS THE LAST PAGE OF THE REPORT



Chain of Custody

Matrix Water - Potable
Analyte Lead
Analysis Type ICP-AES
Container Bottle 250 ml
Project 221899
Client Lead Testing Services
Site Address 1231 N Broad St, Philadelphia, PA
Location
Turnaround 72 Hour
Field Tech Lauren Mitchell
Sample Notes
Chain of Custody Notes

Additional Analytes

Sample Number	Location	Description	Received Condition	Date	Notes
221899-07-023-01-01	5th Floor - Staff Bathroom	Sink Flow	Good	7/25/2022	
221899-07-023-01-02	5th Floor - Staff Bathroom	Sink Standing	Good	7/25/2022	
221899-07-023-01-03	5th Floor - Men's #1	Standing	Good	7/25/2022	
221899-07-023-01-04	5th Floor - Men's #1	Flushing	Good	7/25/2022	
221899-07-023-01-05	5th Floor - Men's #2	Standing	Good	7/25/2022	
221899-07-023-01-06	5th Floor - Men's #2	Flushing	Good	7/25/2022	
221899-07-023-01-07	5th Floor - Women's #1	Standing	Good	7/25/2022	
221899-07-023-01-08	5th Floor - Women's #1	Flushing	Good	7/25/2022	
221899-07-023-01-09	5th Floor - Women's #2	Standard	Good	7/25/2022	
221899-07-023-01-10	5th Floor - Women's #2	Flushing	Good	7/25/2022	
221899-07-023-01-11	Starbucks Sink #1	Standing	Good	7/25/2022	
221899-07-023-01-12	Starbucks Sink #2	Flushing	Good	7/25/2022	
221899-07-023-01-13	Starbucks Sink #1	Flushing	Good	7/25/2022	
221899-07-023-01-14	Starbucks Sink #2	Standing	Good	7/25/2022	
221899-07-023-01-15	Student Bath Sink #1	Standing	Good	7/25/2022	
221899-07-023-01-16	Student Bath Sink #1	Flushing	Good	7/25/2022	
221899-07-023-01-17	Student Sink #2	Standing	Good	7/25/2022	
221899-07-023-01-18	Student Sink #2	Flushing	Good	7/25/2022	
221899-07-023-01-19	5th Floor Water Fountain	Standing	Good	7/25/2022	
221899-07-023-01-20	5th Floor Water Fountain	Flushing	Good	7/25/2022	
221899-07-023-01-21	4th Floor - Kitchen Sink #1	Standing	Good	7/25/2022	



Chain of Custody

221899-07-023-01-22	4th Floor - Kitchen Sink #1	Flushing	Good	7/25/2022
221899-07-023-01-23	4th Floor - Kitchen Sink #2	Standing	Good	7/25/2022
221899-07-023-01-24	4th Floor - Kitchen Sink #2	Flushing	Good	7/25/2022
221899-07-023-01-25	4th Floor - Kitchen Sink #3	Standing	Good	7/25/2022
221899-07-023-01-26	4th Floor - Kitchen Sink #3	Flushing	Good	7/25/2022
221899-07-023-01-27	4th Floor - Kitchen Sink #4	Standing	Good	7/25/2022
221899-07-023-01-28	4th Floor - Kitchen Sink #4	Flushing	Good	7/25/2022
221899-07-023-01-29	4th Floor - Kitchen Sink #5	Standing	Good	7/25/2022
221899-07-023-01-30	4th Floor - Kitchen Sink #5	Standing Sink	Good	7/25/2022
221899-07-023-01-31	4th Floor - Men's Sink #1	Standing	Good	7/25/2022
221899-07-023-01-32	4th Floor - Men's Sink #1	Flushing	Good	7/25/2022
221899-07-023-01-33	4th Floor - Men's Sink #2	Standing	Good	7/25/2022
221899-07-023-01-34	4th Floor - Men's Sink #2	Flushing	Good	7/25/2022
221899-07-023-01-35	4th Floor - Women's #1	Standing	Good	7/25/2022
221899-07-023-01-36	4th Floor - Women's #1	Flushing	Good	7/25/2022
221899-07-023-01-37	4th Floor - Women's #2	Standing	Good	7/25/2022
221899-07-023-01-38	4th Floor - Women's #2	Flushing	Good	7/25/2022
221899-07-023-01-39	4th Floor - Women's #3	Standing	Good	7/25/2022
221899-07-023-01-40	4th Floor - Women's #3	Flushing	Good	7/25/2022
221899-07-023-01-41	4th Floor - Fountain	Standing	Good	7/25/2022
221899-07-023-01-42	4th Floor - Fountain	Flushing	Good	7/25/2022
221899-07-023-01-43	4th Floor - Women's #1	Standing Ex	Good	7/25/2022
221899-07-023-01-44	4th Floor - Women's #1	Flushing Ex	Good	7/25/2022
221899-07-023-01-45	4th Floor - Women's #2	Standing Ex	Good	7/25/2022
221899-07-023-01-46	4th Floor - Women's #2	Flushing Ex	Good	7/25/2022
221899-07-023-01-47	4th Floor - Women's #3	Standing Ex	Good	7/25/2022
221899-07-023-01-48	4th Floor - Women's #3	Flushing Ex	Good	7/25/2022
221899-07-023-01-49	4th Floor - Men's #1	Standing	Good	7/25/2022
221899-07-023-01-50	4th Floor - Men's #1	Flushing	Good	7/25/2022
221899-07-023-01-51	4th Floor - Men's #2	Standing	Good	7/25/2022
221899-07-023-01-52	4th Floor - Men's #2	Flushing	Good	7/25/2022
221899-07-023-01-53	4th Floor - Men's #3	Standing	Good	7/25/2022
221899-07-023-01-54	4th Floor - Men's #3	Flushing	Good	7/25/2022



Chain of Custody

221899-07-023-01-55	4th Floor - Fountain	Standing	Good	7/25/2022
221899-07-023-01-56	4th Floor - Fountain	Flushing	Good	7/25/2022
221899-07-023-01-57	4th Floor - Kitchen	Standing Ex	Good	7/25/2022
221899-07-023-01-58	4th Floor - Kitchen	Flushing Ex	Good	7/25/2022
221899-07-023-01-59	3rd Floor - Men's #1	Standing	Good	7/25/2022
221899-07-023-01-60	3rd Floor - Men's #1	Flushing	Good	7/25/2022
221899-07-023-01-61	3rd Floor - Men's #2	Standing	Good	7/25/2022
221899-07-023-01-62	3rd Floor - Men's #2	Flushing	Good	7/25/2022
221899-07-023-01-63	3rd Floor - Men's #3	Standing	Good	7/25/2022
221899-07-023-01-64	3rd Floor - Men's #3	Flushing	Good	7/25/2022
221899-07-023-01-65	3rd Floor - Kitchen #1	Standing	Good	7/25/2022
221899-07-023-01-66	3rd Floor - Kitchen #1	Flushing	Good	7/25/2022
221899-07-023-01-67	3rd Floor - Women's #1	Standing	Good	7/25/2022
221899-07-023-01-68	3rd Floor - Women's #1	Flushing	Good	7/25/2022
221899-07-023-01-69	3rd Floor - Women's #2	Standing	Good	7/25/2022
221899-07-023-01-70	3rd Floor - Women's #2	Flushing	Good	7/25/2022
221899-07-023-01-71	3rd Floor - Fountain	Standing	Good	7/25/2022
221899-07-023-01-72	3rd Floor - Fountain	Flushing	Good	7/25/2022
221899-07-023-01-73	2nd Floor - Fountain	Standing	Good	7/25/2022
221899-07-023-01-74	2nd Floor - Fountain	Flushing	Good	7/25/2022
221899-07-023-01-75	2nd Floor - Women's #1	Standing	Good	7/25/2022
221899-07-023-01-76	2nd Floor - Women's #1	Flushing	Good	7/25/2022
221899-07-023-01-77	2nd Floor - Women's #2	Standing	Good	7/25/2022
221899-07-023-01-78	2nd Floor - Women's #2	Flushing	Good	7/25/2022
221899-07-023-01-79	2nd Floor - Women's Staff #1	Standing	Good	7/25/2022
221899-07-023-01-80	2nd Floor - Women's Staff	Flushing	Good	7/25/2022
221899-07-023-01-81	2nd Floor - Men's #1	Standing	Good	7/25/2022
221899-07-023-01-82	2nd Floor - Men's #1	Flushing	Good	7/25/2022
221899-07-023-01-83	2nd Floor - Men's #2	Standing	Good	7/25/2022
221899-07-023-01-84	2nd Floor - Men's #2	Flushing	Good	7/25/2022
221899-07-023-01-85	1st Floor #1	Standing	Good	7/25/2022
221899-07-023-01-86	1st Floor #1	Flushing	Good	7/25/2022

Sample Count 86

Handling Chain Type	Handled By	Date	Time	Notes
Report Results To	Lead Testing Services	7/23/2022		
Send Reports To	Lead Testing Services	7/23/2022		
Samples Taken By	Lead Testing Services	7/23/2022	07:00	
Transported By	Lead Testing Services	7/25/2022	12:00	
Relinquished By	Lead Testing Services	7/25/2022	12:06	
Received By	Lauren Mitchell	7/25/2022	12:26	
Analyzed By	Andrew Schwab	7/27/2022	16:00	
Reviewed By	Collin Marrs	7/28/2022	10:30	